

# TEST REPORT

For

Tablet

Model/Spec.: RT3

Report No.: WT226400852

Test Laboratory : Shenzhen Academy of Metrology and Quality Inspection  
Site Location : Songshanhu Lab, No.7 of Industrial North Road, Songshan  
Lake Hi-Tech Industrial Zone, Dongguan, Guangdong.  
Tel : 0086-769-23324610  
Fax : 0086-769-23324601  
Web : www.smq.com.cn

# 重要声明

## Important statement

1. 本院是深圳市人民政府依法设置的产品质量监督检验机构,系社会公益型非营利性技术机构,为各级政府执法部门进行监督管理提供技术支持和接受社会各界的委托检验。

SMQ is a legal non-profit technical institute established by Shenzhen Municipal Government to undertake the quality supervision and inspection of products, and to provide technical support to relevant supervision and administration and also conduct commission test from the society.

2. 本院保证检验的科学性、公正性和准确性,对检验的数据负责,并对委托单位所提供的样品和技术资料保密。

SMQ is committed to assuring the scientificness, impartiality and accuracy of all tests carried out, responsibility for test data gained, and keeping confidential of all test samples and technical documents provided.

3. 抽样按照本院程序文件《抽样程序》和相应产品的检验细则的规定执行。

The sampling should be carried out according to the "sampling procedure" defined in the Procedure Document and relevant testing specifications.

4. 报告/证书无主检、审核、批准人签字,或涂改,或未盖本院报告/证书专用章及骑缝章无效。未经本院许可,不得部分复印、摘用或篡改本报告/证书内容。复印证书/报告未重新加盖本院证书/报告专用章无效。

Any report/certificate having not been signed by relevant responsible engineer, reviewer or authorized approver, or having been altered without authorization, or without both the Dedicated Report/Certificate Seal and its across-page seal is deemed to be invalid. Copying or excerpting portion of, or altering the content of the report/certificate is not permitted without the written authorization of SMQ. Any copy of certificates/reports without the Dedicated Report/Certificate Seal is deemed to be invalid.

5. 送样委托检验结果仅对来样有效:委托检验的样品、样品及委托方信息均由委托方提供,本院不对样品的代表性、真实性及信息的完整性和准确性负责。

The test results presented in the report apply only to the tested sample. The customer provides thier own information, the sample, and the sample information. Thus, SMQ assumes no responsibility for representativeness, authenticity of the sample and validity and accuracy of the information.

6. 未经检验机构同意,样品委托人不得擅自使用检验结果进行不当宣传。

Any use of SMQ test result for advertisement of the tested material or product must be approved in writing by SMQ.

7. 无 CMA 标志的报告/证书,仅作为科研、教学或内部质量控制之用。含粤字编号的 CAL 标志仅适用于产品标准和判定标准。

The non-CMA report/certificate issued by SMQ is only permitted to be used for research, teaching or internal quality control. CAL logo with symbol "Yue" is only relevant to product standards and reference of standards.

8. 委托方对报告/证书有异议的,应于报告发出之日起十五日内向本院提出。政府行政管理部门下达的监督检验任务,受检方对报告/证书有异议的,应按政府行政管理部门文件规定及国家相关法律、法规进行。

Any objection to report/certificate issued by SMQ should be submitted to SMQ within 15 days after the issuance of the test. The mandatory inspection assigned by government administrative departments shall be carried out in accordance with the documents and regulations of the government administrative department and relevant national laws and regulations if inspected parties raise any objection to the inspection.

9. 报告/证书更改后,发出的电子版报告/证书、报告/证书的扫描件及传真件将不被追回,委托方有义务将更改后的报告/证书提供给使用原报告/证书的相关方。

SMQ is not responsible for recalling the electronic version of the original report/certificate when any revision is made to them. The applicant assumes the responsibility of providing the revised version to any interested party who uses them.

10. 只申领电子报告时,相关内容和效力以电子报告为准;电子报告和纸质报告同时申领时,电子报告仅作为纸质报告的副本,相关内容和效力以同编号纸质报告为准。

The relevant content and effectiveness is subject to the electronic version of the original report which was only applied for. When an electronic report and a paper report are applied for at the same time, the electronic report is only a copy of the paper report, and the relevant content and effectiveness is subject to the paper report.

11. 检验报告二维码具浏览和下载完整报告功能,是应委托方要求所设,该二维码及其复制图能使任何人扫描获取完整的检验报告电子版,本报告持有人如需限制他人经该二维码获取检验报告内容,应自行遮盖或消除检验报告及其复制件所附二维码,我院对委托方选择检验报告二维码功能所致的信息泄露概不负责(适用于附二维码报告)。

The QR code has the function of browsing and downloading complete report. Setting this function or not is chosen by the customer. The QR code and its copy enable anyone to scan and obtain the complete electronic version of the test report. Thus, if the owner of this report needs to restrict others from obtaining the content of the test report through the QR code, he shall cover or remove the QR code attached to the test report and its copies by himself. SMQ assumes no responsibility for the information leakage caused by the customer's selection of the QR code function of the test report (This clause applies to reports with QR code attached).

### 投诉及报告/证书真伪查询电话

Complaint hotline: 400-900-8999 按 5

Email: complaint@smq.com.cn

### Test Report Declaration

Applicant : SHENZHEN YUNJI INTELLIGENT TECHNOLOGY CO., LTD  
Address : 202, Building A2, Silicon Valley Power Intelligent Terminal Industrial Park, No.20, Dafu Industrial Zone, Kukeng Community, Guanlan Street, Longhua District, Shenzhen  
Manufacturer : SHENZHEN YUNJI INTELLIGENT TECHNOLOGY CO., LTD  
Address : 202, Building A2, Silicon Valley Power Intelligent Terminal Industrial Park, No.20, Dafu Industrial Zone, Kukeng Community, Guanlan Street, Longhua District, Shenzhen  
Factory : SHENZHEN YUNJI INTELLIGENT TECHNOLOGY CO., LTD  
Address : 202, Building A2, Silicon Valley Power Intelligent Terminal Industrial Park, No.20, Dafu Industrial Zone, Kukeng Community, Guanlan Street, Longhua District, Shenzhen  
Specimen : Tablet  
Trade mark : OUKITEL  
Model/Spec. : RT3  
Specimen quantity : 1 pc  
Serial/Specimen No. : N/A  
Manufactured date : Nov.03,2022  
Specimen source : Submitted by applicant  
Received date : Nov.04,2022  
Processed date : Nov.07,2022  
Test criteria : MIL-STD-810H:2019  
Acceptance criteria : Same as test criteria

Tested by:	<u>Zhu Zhi Tong</u>	Date:	<u>Nov.11,2022</u>
Checked by:	<u>You Shuifu</u>	Date:	<u>Nov.11,2022</u>
Approved by:	<u>Chen Xiangyu</u>	Date:	<u>Nov.11,2022</u>

## TABLE OF CONTENTS

<b>1</b>	<b>TEST SUMMARY .....</b>	<b>4</b>
<b>2</b>	<b>AMBIENT CONDITION .....</b>	<b>4</b>
<b>3</b>	<b>INITIAL CHECK .....</b>	<b>4</b>
<b>4</b>	<b>LOW PRESSURE(ALTITUDE)TEST .....</b>	<b>5</b>
	4.1 Test Requirement.....	5
	4.2 Acceptance Criteria.....	5
	4.3 Test Result.....	5
	4.4 Test Conclusion .....	5
	4.5 Photo and Profile.....	6
	<b>APPENDIX A EQUIPMENT USED FOR TEST .....</b>	<b>8</b>

## 1 TEST SUMMARY

Table 1 Test overview

Test Items	Specimen status	Serial/Specimen No.	Test conclusion	Processed date
Low pressure (Altitude) test	Unpackaged, operating	N/A	Pass	Nov.07, 2022

## 2 AMBIENT CONDITION

Temperature: (25~27)°C  
Relative Humidity: (52~54)%  
Atmospheric Pressure: (101~102)kPa

## 3 INITIAL CHECK

Before the test, the specimen exhibited no mechanical damage or functional failure.

(to next page)

## 4 LOW PRESSURE(ALTITUDE)TEST

### 4.1 Test Requirement

Test criteria: Refer to MIL-STD-810H:2019 method 500.6, procedure II

Specimen status: Unpackaged, operating

Altitude:15000ft

Air pressure:57.2kPa

Pressure tolerance:  $\pm 5\%$

Rate of pressure change:  $\leq 10\text{m/s}$

Test temperature:( $25\pm 2$ ) $^{\circ}\text{C}$

Test duration: 4h

Recovery duration: 2h

### 4.2 Acceptance Criteria

During the test, the specimen should exhibit no functional failure.

After the test, the specimen should exhibit no appearance damage or functional failure.

### 4.3 Test Result




During the test, the specimen exhibited no functional failure.

After the test, the specimen exhibited no appearance damage or functional failure.


### 4.4 Test Conclusion

Pass

### 4.5 Photo and Profile

 A photograph of a smartphone with a colorful home screen, placed on a blue surface.	 A photograph showing the interior of a test chamber with a metal mesh floor. A smartphone is lying on the floor.
<p>No.4-1 Inspection before test</p>	<p>No.4-2 Low pressure (Altitude) test specimen setting</p>
 A photograph of the same smartphone, showing the home screen, placed on a blue surface.	<p>N/A</p>
<p>No.4-3 Inspection after test</p>	

(to next page)



No.4-4 Low pressure (Altitude) test profile

(to next page)



## APPENDIX A EQUIPMENT USED FOR TEST

Table 2 Test equipment used

No.	Equipment	Equipment ID	Type	Manufacturer	Due date
1	Low air pressure chamber	SB19210	QDS62	Yin He	Jan.06,2023

(The end)



# TEST REPORT

Report No. :BJ-R221121101A-EN

Test Item :IPX9K Test

Client :SHENZHEN YUNJI INTELLIGENT TECHNOLOGY  
CO.,LTD

Address :202, Building A2, Silicon Valley Power Intelligent  
Terminal Industrial Park, No. 20, Kukeng Dafu  
Industrial Zone, Kukeng Community, Guanlan  
Street, Longhua District, Shenzhen

ShenZhen BestJ Testing Technologies Co., Ltd

Inspected Engineer: Liu Yuehui

Date: Nov.23,2022

Reviewed Engineer: Luo Ningsheng

Date: Nov.23,2022

Authorized Signatory: Zhang Jianbiao

Date: Nov.23,2022



# Content

1.SAMPLE INFORMATION .....	2
2.TEST INFORMATION .....	2
3.TEST RESULTS .....	2
4.IPX9K Test .....	3
4.1 Reference Standard .....	3
4.2 Laboratory Environment .....	3
4.3 Test Equipment .....	3
4.4 Test Procedure .....	3
4.5 Test Conditions .....	4
4.6 Test Photos .....	5

**1.SAMPLE INFORMATION**

Sample Name	Tablet
Sample Mode	RT3
Sample No.	BJ-R221121101A-1#
Sample Size	/
Weight Of Sample	/
Sample Quantity	1 PC
Manufacturer	SHENZHEN YUNJI INTELLIGENT TECHNOLOGY CO.,LTD
Address	202, Building A2, Silicon Valley Power Intelligent Terminal Industrial Park, No. 20, Kukeng Dafu Industrial Zone, Kukeng Community, Guanlan Street, Longhua District, Shenzhen
Sample Source	Commissioned units send sample
Inspection Type	Commissioning test
Sample Description	Sample appearance is good

**2.TEST INFORMATION**

Test Items	Received Date	Date Of Test(s)
IPX9K Test	Nov.21,2022	Nov.22,2022

**3.TEST RESULTS**

Test Items	Test Results
IPX9K Test	After test, there was no water enter the enclosure of sample, and the function was normal.

## 4.IPX9K Test

### 4.1 Reference Standard

Test according to ISO 20653-2013 Road vehicles - Degrees of protection (IP code) - Protection of electrical equipment against foreign objects, water and access


### 4.2 Laboratory Environment

Ambient temperature: $25\pm 3^{\circ}\text{C}$       Relative humidity: $55\pm 20\%\text{RH}$

### 4.3 Test Equipment


Test Equipment	Equipment Model	Calibration Date
Hi-Temp&Hi-Pressure Water Injection Test Chamber	TL-IPX9K-1000	Apr. 19,2022

### 4.4 Test Procedure



#### 4.5 Test Conditions

Water temperature	$80 \pm 5^{\circ}\text{C}$
pressure	(8000~10000) kPa
Water flow	14~16L/min
distance	10~15cm
Angle and time	$0^{\circ}$ 、 $30^{\circ}$ 、 $60^{\circ}$ 、 $90^{\circ}$ 30 seconds per angle



### 4.6 Test Photos


#### Before test



#### Test setup



After test






# 报告说明

- 1.检测地点:  
Place for the testing:  
  
深圳市宝安区航城街道南昌路华丰工业园 B 栋一楼。  
1/F, Fengze Building B, The Second Industrial Park of Huafeng, Nanchang Road, Hangcheng Street, Baoan District, Shenzhen.
- 2.本报告无 BTT 报告章无效。  
This report is considered invalidated without the Special Seal for Inspection of the BTT.
- 3.本报告不得涂改、删减。  
This report shall not be altered, added and deleted.
- 4.本报告只对采样/送检样品检测结果负责。  
The results relate only to the items tested.
- 5.本报告未经同意不得作为商业广告使用。  
This report shall not be published as advertisement without the approval of BTT.
- 6.本报告内容仅供委托方内部参考使用，本报告的最终解释权归本公司所有。  
The contents of this report are for internal reference of the commissioning party only. The final interpretation right of this report belongs to BTT.
- 7.未经 BTT 书面批准，不得部分复制检测报告。  
This report shall not be copied partly without the written approval of BTT.
- 8.对本报告有异议，请在收到报告 10 天之内与本公司联系。  
Please contact with us within 10 days after you received the report if you have any questions with it.
- 9.除客户特别申明并支付样品管理费，所有超过标准规定失效期的样品均不再做留样。  
All expired samples which exceed standard time limited will not be remained, unless clients have special declaration with payment.
- 10.除客户特别申明并支付档案管理费，本次检测的所有记录档案保存期为三年。  
All of the testing record would be kept for three years unless the customer declares and pays administration fee in advance.

\*\*\*报告结束 End of report\*\*\*

<b>TEST REPORT</b> <b>IEC/EN 60529</b> <b>Degrees of protection provided by enclosures (IP code)</b>	
<b>Report Number</b> .....	JYTSZ-R09-2200445
<b>Date of issue</b> .....	Nov. 28, 2022
<b>Total number of pages</b> .....	21
<b>Applicant's name</b> .....	SHENZHEN YUNJI INTELLIGENT TECHNOLOGY CO., LTD
<b>Address</b> .....	202, Building A2, Silicon Valley Power Intelligent Terminal Industrial Park, No. 20, Kukeng Dafu Industrial Zone, Kukeng Community, Guanlan Street, Longhua District, Shenzhen, China
<b>Test specification:</b>	
<b>Standard</b> .....	IEC 60529: 1989 + AMD1: 1999 + AMD2: 2013 EN 60529: 1992 + A2:2013
<b>Test procedure</b> .....	Test Report
<b>Non-standard test method</b> .....	N/A
<b>Test Report Form No.</b> .....	IEC60529B
<b>Test Report Form(s) Originator</b> .....	JYTSZ
<b>Master TRF</b> .....	Dated 2022-02-15
<b>General disclaimer:</b>	
<p>The test results presented in this report relate only to the object tested.</p> <p>This report shall not be reproduced, except in full, without the written approval by Jianyan Testing Group Shenzhen Co., Ltd.</p> <p>The authenticity of this Test Report and its contents can be verified by Jianyan Testing Group Shenzhen Co., Ltd., responsible for this Test Report.</p>	
<b>Test item description</b> .....	Tablet
<b>Trade Mark</b> .....	N/A
<b>Manufacturer</b> .....	SHENZHEN YUNJI INTELLIGENT TECHNOLOGY CO., LTD
<b>Address</b> .....	202, Building A2, Silicon Valley Power Intelligent Terminal Industrial Park, No. 20, Kukeng Dafu Industrial Zone, Kukeng Community, Guanlan Street, Longhua District, Shenzhen, China
<b>Model/Type reference</b> .....	RT3
<b>Ratings</b> .....	IP68

<b>Testing procedure and testing location:</b>	
Testing Laboratory..... :	Jiayan Testing Group Shenzhen Co., Ltd.
Testing location/ address..... :	No. 101, Building 8, Innovation Wisdom Port, No. 155hongtian Road, Huangpu Community, Xinqiao Street, Bao'an District, Shenzhen, Guangdong, People's Republic of China.
Prepare by (name + signature) ..... :	Seul Wu <span style="float: right;"><i>Seul Wu</i></span>
Reviewed by (name + signature) .. :	Joy Yi <span style="float: right;"><i>Joy Yi</i></span>
Approved by (name + signature) ... :	Daniel Li
<b>Summary of testing:</b>	
<b>Tests performed (name of test and test clause):</b> The submitted samples were tested and found to comply with the requirements of: - IEC 60529: 1989 + AMD1: 1999 + AMD2: 2013 - EN 60529: 1992 + A2:2013	<b>Testing location:</b> Jiayan Testing Group Shenzhen Co., Ltd. No. 101, Building 8, Innovation Wisdom Port, No. 155 Hongtian Road, Huangpu Community, Xinqiao Street, Bao'an District, Shenzhen, Guangdong, People's Republic of China.
<b>Summary of compliance with National Differences</b> List of countries addressed: National Differences and Group Differences. <input checked="" type="checkbox"/> The product fulfils the requirements of <u>EN 60529: 1992 + A2:2013.</u>	
<b>Copy of marking plate: N/A</b>	

<b>Test item particulars</b> ..... :	
Classification of installation and use..... :	IP68
Supply Connection..... :	<input type="checkbox"/> EUT with cable and plug <input checked="" type="checkbox"/> EUT without cable and plug
<b>Possible test case verdicts</b> ..... :	
- test case does not apply to the test object..... :	N/A
- test object does meet the requirement..... :	P (Pass)
- test object does not meet the requirement..... :	F (Fail)
<b>Testing</b> .....	
Date of receipt of test item..... :	Nov.16, 2022
Date (s) of performance of tests .....	Nov.21, 2022 to Nov.23, 2022
<b>General remarks:</b>	
"(See Enclosure #)" refers to additional information appended to the report. "(See appended table)" refers to a table appended to the report.	
Throughout this report a <input type="checkbox"/> comma / <input checked="" type="checkbox"/> point is used as the decimal separator.	
<b>Name and address of factory (ies)</b> ..... :	
SHENZHEN YUNJI INTELLIGENT TECHNOLOGY CO., LTD 202, Building A2, Silicon Valley Power Intelligent Terminal Industrial Park, No. 20, Kukeng Dafu Industrial Zone, Kukeng Community, Guanlan Street, Longhua District, Shenzhen, China	
<b>General product information:</b>	
All the testing were carried out as applicable. This report covers IP68 degree related tests to evaluate water and dust: results passed;	
Picture of the product:	
	

IEC 60529			
Clause	Requirement + Test	Result - Remark	Verdict
10	<b>Marking</b>		—
	The requirements for marking shall be specified in the relevant product standard.	IP68	P
	Where appropriate, such a standard should also specify the method of marking which is to be used when:		P
	one part of an enclosure has a different degree of protection to that of another part of the same enclosure		P
	the mounting position has an influence on the degree of protection		P
	the maximum immersion depth and time are indicated		N/A

11	<b>General requirements for tests</b>		—
11.1	<b>Atmospheric conditions for water or dust tests</b>		—
	Unless otherwise specified in the relevant product standard, the tests should be carried out under the standard atmospheric conditions described in IEC 60068-1.		P
	The recommended atmospheric conditions during the tests are as follows:		—
	Temperature range: 15 to 35°C Relative humidity: 25 to 75% Air pressure: 86 to 106 kPa (860 to 1060 mbar)		P
11.2	<b>Test samples</b>		P
	The tests specified in this standard are type tests.		P
	Unless otherwise specified in a relevant product standard, the test samples for each test shall be in a clean and new condition, with all parts in place and mounted in the manner stated by the manufacturer.		P
	If it is impracticable to test the complete equipment, representative parts or smaller equipment having the same full-scale design details shall be tested		N/A
	The relevant product standard shall specify details such as:		P
	the number of samples to be tested;		P
	the conditions for mounting, assembling and positioning of the samples, for example by the use of an artificial surface (ceiling, floor or wall);		P
	the pre-conditioning, if any, which is to be used;		P
	whether to be tested energized or not;		N/A

IEC 60529				
Clause	Requirement + Test		Result - Remark	Verdict
	whether to be tested with its parts in motion or not.			N/A
	In the absence of such specification, the manufacturer's instructions shall apply.			P
11.3	<b>Application of test requirements and interpretation of test results</b>			—
	The application of the general requirements for tests and the acceptance conditions for equipment containing drain-holes or ventilation openings is the responsibility of the relevant technical Committee.			N/A
	In the absence of such specification the requirement of this standard shall apply.			P
	The interpretation of test results is the responsibility of the relevant Technical Committee. In the absence of a specification the acceptance of a specification the acceptance conditions of this standard shall at least apply			P
11.4	<b>Combination of test conditions for the first characteristic numeral</b>			—
	Designation with a first characteristic numeral implies that all test conditions are met for this numeral:			P
	Table 5 – Test conditions for degrees of protection indicated by the first characteristic numeral			—
	<b>First characteristic numeral</b>	<b>Test for protection against</b>		P
		<b>Access to hazardous parts</b>	<b>Solid foreign objects</b>	
	0	No test required	No test required	N/A
	1	The sphere of 50 mm Ø shall not fully penetrate and adequate clearance shall be kept		N/A
	2	The jointed test finger may penetrate up to its 80 mm length, but adequate clearance shall be kept	The sphere of 12.5 mm Ø shall not fully penetrate	N/A
	3	The test rod of 2.5 mm Ø shall not penetrate and adequate clearance shall be kept		N/A
	4	The test wire of 1.0 mm Ø shall not penetrate and adequate clearance shall be kept		N/A
	5	The test wire of 1.0 mm Ø shall not penetrate and adequate clearance shall be kept	Dust-protected as specified in table 2	N/A
	6	The test wire of 1.0 mm Ø shall not penetrate and adequate clearance shall be kept	Dust-tight as specified in table 2	P
11.5	<b>Empty enclosures</b>			—

IEC 60529			
Clause	Requirement + Test	Result - Remark	Verdict
	If the enclosure is tested without equipment inside, detailed requirements shall be indicated by the enclosure manufacturer in his instructions for the arrangement and spacing of hazardous parts or parts which might be affected by the penetration of foreign objects or water.	Enclosure is tested with equipment inside	N/A
	The manufacturer of the final assembly shall ensure that after the electrical equipment is enclosed the enclosure meets the declared degree of protection of the final product.		N/A

12	<b>Tests for protection against access to hazardous parts indicated by the first characteristic numeral</b>		—
12.1	<b>Access probes</b>		—
	Access probes to test the protection of persons against access to hazardous parts are given in table 6.		N/A
12.2	<b>Test conditions</b>		—
	The access probe is pushed against or (in case of the test for first characteristic numeral 2) inserted through any openings of the enclosure with the force specified in table 6.		N/A
	For tests on low-voltage equipment, a low-voltage supply (of not less than 40 V and not more than 50 V) in series with a suitable lamp should be connected between the probe and the hazardous parts inside the enclosure. Hazardous live parts covered only with varnish or paint, or protected by oxidation or by a similar process, are covered by a metal foil electrically connected to those parts which are normally live in operation.		N/A
	The signal-circuit method should also be applied to the hazardous moving parts of high-voltage equipment.		N/A
	Internal moving parts may be operated slowly, where this is possible.		N/A
12.3	<b>Acceptance conditions</b>		—
	The protection is satisfactory if adequate clearance is kept between the access probe and hazardous parts.		N/A
	For the test of first characteristic numeral 1, the access probe 50 mm diameter shall not completely pass through the opening.		N/A

IEC 60529			
Clause	Requirement + Test	Result - Remark	Verdict
	For the test of first characteristic numeral 2, the jointed test finger may penetrate to its 80 mm length, but the stop face (Ø 50 x 20 mm) shall not pass through the opening. Starting from the straight position, both joints of the test finger shall be successively bent through an angle of up to 90° with respect to the axis of the adjoining section of the finger and shall be placed in every possible position.		N/A
	See Annex A for further clarification. Adequate clearance means		N/A
12.3.1	<b>For low-voltage equipment</b> (rated voltages not exceeding 1000 V a.c. and 1500 V d.c.)		—
	The access probe shall not touch hazardous live parts.		N/A
	If adequate clearance is verified by a signal circuit between the probe and hazardous parts, the lamp shall not light.		N/A
12.3.2	<b>For high-voltage equipment</b> (rated voltages exceeding 1000 V a.c. and 1500 V d.c.)		—
	When the access probe is placed in the most unfavourable position(s), the equipment shall be capable of withstanding the dielectric tests as specified in the relevant product standard applicable to the equipment.		N/A
	Verification may be made either by dielectric test or by inspection of the specified clearance dimension in air which would ensure that the tests would be satisfactory under the most unfavourable electric field configuration (see IEC 60071-2).		N/A
	In the case where an enclosure includes sections at different voltage levels the appropriate acceptance conditions for adequate clearance shall be applied for each section.		N/A
12.3.3	<b>For equipment with hazardous mechanical parts</b>		—
	The access probe shall not touch hazardous mechanical parts.		N/A
	If adequate clearance is verified by a signal circuit between the probe and hazardous parts, the lamp shall not light.		N/A
13	<b>Tests for protection against solid foreign objects indicated by the first characteristic numeral</b>		—
13.1	<b>Test means</b>		—
	Test means and the main test conditions are given in table 7.		P



IEC 60529					
Clause	Requirement + Test		Result - Remark		Verdict
	<b>Table 7 – Test means for the tests for protection against solid foreign objects</b>				—
	<b>First characteristic numeral</b>	<b>Test means</b>	<b>Test force</b>	<b>Test conditions</b>	—
	0	No test required	—	—	N/A
	1	Rigid sphere without handle or guard 50 mm diameter	50 N ±10%	13.2	N/A
	2	Rigid sphere without handle or guard 12,5 mm diameter	30 N ±10%	13.2	N/A
	3	Rigid steel rod 2.5 mm diameter with edges free from burrs	3 N ±10%	13.2	N/A
	4	Rigid steel wire 1 mm diameter with edges free from burrs	1 N ±10%	13.2	N/A
	5	Dust chamber Figure 2, with or without underpressure	—	13.4 and 13.5	N/A
	6	Dust chamber Figure 2, with underpressure	—	13.4 and 13.6	P
13.2	<b>Test conditions for first characteristic numerals 1, 2, 3, 4</b>				—
	The object probe is pushed against any openings of the enclosure with the force specified in table 7.				N/A
13.3	<b>Acceptance conditions for first characteristic numerals 1, 2, 3, 4</b>				—
	The protection is satisfactory if the full diameter of the probe specified in table 7 does not pass through any opening.				N/A
13.4	<b>Dust test for first characteristic numerals 5 and 6</b>				—
	The test is made using a dust chamber incorporating the basic principles shown in figure 2 whereby the powder circulation pump may be replaced by other means suitable to maintain the talcum powder in suspension in a closed test chamber. The talcum powder used shall be able to pass through a square-meshed sieve the nominal wire diameter of which is 50 um and the nominal width of a gap between wires 75 um. The amount of talcum powder to be used is 2 kg per cubic metre of the test chamber volume. It shall not have been used for more than 20 tests.		IP68		P
	Enclosures are of necessity in one of two categories:				—

IEC 60529			
Clause	Requirement + Test	Result - Remark	Verdict
	Category 1: Enclosures where the normal working cycle of the equipment causes reductions in air pressure within the enclosure below that of the surrounding air, e.g., due to thermal cycling effects.		P
	Category 2: Enclosures where no pressure difference relative to the surrounding air is present		N/A
	Category 1 enclosures:		—
	The enclosure under test is supported inside the test chamber and the pressure inside the enclosure is maintained below the surrounding atmospheric pressure by a vacuum pump.		P
	The suction connection shall be made to a hole specially provided for this test.		P
	If not otherwise specified in the relevant product standard, this hole shall be in the vicinity of the vulnerable parts.		N/A
	If it is impracticable to make a special hole, the suction connection shall be made to the cable inlet hole.		N/A
	If there are other holes (e.g., more cable inlet holes or drain-holes) these shall be treated as intended for normal use on site.		P
	The object of the test is to draw into the enclosure, by means of depression, a volume of air 80 times the volume of the sample enclosure tested without exceeding the extraction rate of 60 volumes per hour.		P
	In no event shall the depression exceed 2 kPa (20 mbar) on the manometer shown in figure 2.		P
	If an extraction rate of 40 to 60 volumes per hour is obtained the duration of the test is 2 h.		N/A
	If, with a maximum depression of 2 kPa (20 mbar), the extraction rate is less than 40 volumes per hour, the test is continued until 80 volumes have been drawn through, or a period of 8 h has elapsed.		P
	or a period of 8 h has elapsed.		N/A
	Category 2 enclosures:		—
	The enclosure under test is supported in its normal operating position inside the test chamber, but is not connected to a vacuum pump.		N/A
	Any drain-hole normally open shall be left open for the duration of the test.		N/A
	The test shall be continued for a period of 8h		N/A
	Category 1 and category 2 enclosures:		—

IEC 60529			
Clause	Requirement + Test	Result - Remark	Verdict
	If it is impracticable to test the complete enclosure in the test chamber, one of the following procedures shall be applied:		N/A
	testing of individually enclosed sections of the enclosure;		N/A
	testing of representative parts of the enclosure, comprising components such as doors, ventilation openings, joints, shaft seals, etc., in position during test;		N/A
	testing of a smaller enclosure having the same full-scale design details.		N/A
	In the last two cases, the volume of air to be drawn through the enclosure under test shall be the same as for the whole enclosure in full scale		N/A
13.5	<b>Special conditions for first characteristic numeral 5</b>		—
13.5.1	<b>Test conditions for first characteristic numeral 5</b>		—
	The enclosure shall be deemed category 1 unless the relevant product standard for the equipment specifies that the enclosure is category 2.		N/A
13.5.2	<b>Acceptance conditions for first characteristic numeral 5</b>		—
	The protection is satisfactory if, on inspection, talcum powder has not accumulated in a quantity or location such that, as with any other kind of dust, it could interfere with the correct operation of the equipment or impair safety.		N/A
	Except for special cases to be clearly specified in the relevant product standard, no dust shall deposit where it could lead to tracking along the creepage distances.		N/A
13.6	<b>Special conditions for first characteristic numeral 6</b>		—
13.6.1	<b>Test conditions for first characteristic numeral 6</b>		—
	The enclosure shall be deemed category 1, whether reductions in pressure below the atmospheric pressure are present or not.		P
13.6.2	<b>Acceptance conditions for first characteristic numeral 6</b>		—
	The protection is satisfactory if no deposit of dust is observable inside the enclosure at the end of the test.	No dust enters after test	P
14	<b>Tests for protection against water indicated by the second characteristic numeral</b>		—
14.1	<b>Test means</b>		—
	The test means and the main test conditions are given in table 8.		P

IEC 60529						
Clause	Requirement + Test			Result - Remark		Verdict
	<b>Table 8 – Test means and main test conditions for the tests for protection against water</b>					—
	Second charact. numeral	Test means	Water flow rate	Duration of test	Test conditions	—
	0	No test required	—	—	—	N/A
	1	Drip box Figure 3 Enclosure on turntable	1 mm/min	10 min	14.2.1	N/A
	2	Drip box Figure 3 Enclosure in 4 fixed positions of 15° tilt	3 mm/min	2.5 min for each position of tilt	14.2.2	N/A
	3	Oscillating tube Figure 4 Spray ± 60° from vertical, distance max. 200 mm	0.07 l/min ± 5% per hole, multiplied by number of holes	10 min	14.2.3 a)	N/A
		or Spray nozzle Figure 5 Spray ± 60° from vertical	10 l/min ± 5%	1 min/m <sup>2</sup> at least 5 min	14.2.3 b)	
	4	As for numeral 3 Spray ± 180° from vertical	As for numeral 3		14.2.4	N/A
	5	Water jet hose nozzle Figure 6 Nozzle 6.3 mm diameter, distance 2.5 m to 3 m	12.5 l/min ± 5%	1 min/m <sup>2</sup> at least 3 min	14.2.5	N/A
	6	Water jet hose nozzle Figure 6 Nozzle 12.5 mm diameter, distance 2.5 m to 3 m	100 l/min ± 5%	1 min/m <sup>2</sup> at least 3 min	14.2.6	N/A
	7	Immersion tank Water-level on enclosure: 0.15 m above top 1 m above bottom	—	30 min	14.2.7	N/A
	8	Immersion tank Water-level: by agreement	—	by agreement	14.2.8	P

IEC 60529						
Clause	Requirement + Test			Result - Remark		Verdict
	9	Fan jet nozzle Figure 7 Test of small enclosure on turntable Figure 12 Turntable speed (5 ± 1) r/min Spray at 0°, 30°, 60°, 90°  Or Test of large enclosures as per intended use Spray from all practical directions Distance (175 ± 25) mm	(15 ± 1) l/min	30 s per position	14.2.9 a)	N/A
				1 min/m <sup>2</sup> at least 3 min	14.2.9 b)	
14.2	<b>Test conditions</b>					—
	Test means and main test conditions are given in Table 8.			IP68		P
	Details concerning compliance of degrees of protection – in particular for second characteristic numerals 5/6 (water jets) and numerals 7/8 (immersion) – are given in Clause 6.					P
	The tests are conducted with fresh water.					P
	During the tests for IPX1 to IPX6 the water temperature should not differ by more than 5 K from the temperature of the specimen under test.					N/A
	If the water temperature is more than 5 K below the temperature of the specimen a pressure balance shall be provided for the enclosure.					N/A
	For IPX7 and IPX9 details of the water temperature are given in 14.2.7 and 14.2.9 respectively.					N/A
	During the test, the moisture contained inside the enclosure may partly condense. The dew which may thus deposit shall not be mistaken for an ingress of water.					P
	For the purpose of the tests, the surface area of the enclosure is calculated with a tolerance of 10%.					P
	Adequate safety precautions should be taken when testing the equipment in the energized condition			Test equipment is power off		N/A
14.2.1	<b>Test for second characteristic numeral 1 with the drip box</b>					—

<b>IEC 60529</b>			
Clause	Requirement + Test	Result - Remark	Verdict
	The test is made with a device which produces a uniform flow of water drops over the whole area of the enclosure.		N/A
	The turntable on which the enclosure is placed has a rotation speed of 1 r/min and the eccentricity (distance between turntable axis and specimen axis) is approximately 100 mm.		N/A
	The enclosure under test is placed in its normal operating position under the drip box, the base of which is larger than that of the enclosure.		N/A
	Except for enclosures designed for wall or ceiling mounting, the support for the enclosure under test should be smaller than the base of the enclosure.		N/A
	An enclosure normally fixed to a wall or ceiling is fixed in its normal position of use to a wooden board having dimensions which are equal to those of that surface of the enclosure which is in contact with the wall or ceiling when the enclosure is mounted as in normal use.		N/A
	The duration of test is 10 min.		N/A
<b>14.2.2</b>	<b>Test for second characteristic numeral 2 with the drip box</b>		—
	The dripping device is the same as specified in 14.2.1 adjusted to provide the water flow rate specified in Table 8.		N/A
	The table on which the enclosure is placed does not turn as in the case of the test for the second characteristic numeral 1.		N/A
	The enclosure is tested for 2,5 min in each of four fixed positions of tilt. These positions are 15° on either side of the vertical in two mutually perpendicular planes (see Figure 3b)).		N/A
	The total duration of the test is 10 min.		N/A
<b>14.2.3</b>	<b>Test for second characteristic numeral 3 with oscillating tube or spray nozzle</b>		—
	The test is made using one of the two test devices described in Figure 4 and in Figure 5 in accordance with the relevant product standard.		N/A
	a) Conditions when using the test device as in Figure 4 (oscillating tube)		N/A
	b) Conditions when using the test device as in Figure 5 (spray nozzle)		N/A
<b>14.2.4</b>	<b>Test for second characteristic numeral 4 with oscillating tube or spray nozzle</b>		—
	The test is made using one of the two test devices described in Figure 4 and in Figure 5 in accordance with the relevant product standard.		N/A
	a) Conditions when using the test device as in Figure 4 (oscillating tube):		N/A

IEC 60529						
Clause	Requirement + Test			Result - Remark		Verdict
	b) Conditions when using the test device as in Figure 5 (spray nozzle):					N/A
	<b>Table 9 – Total water flow rate qv under IPX3 and IPX4 test conditions –Mean flow rate per hole q<sub>vi</sub> = 0.07 l/min</b>					—
	<b>Tube radius R mm</b>	<b>Number of open holes N (1)</b>	<b>Total water flow Qv l/min</b>	<b>Number of open holes 1)</b>	<b>Total water flow qv l/min</b>	—
	200	8	0.56	12	0.84	N/A
	400	16	1.1	25	1.8	N/A
	600	25	1.8	37	2.6	N/A
	800	33	2.3	50	3.5	N/A
	1000	41	2.9	62	4.3	N/A
	1200	50	3.5	75	5.3	N/A
	1400	58	4.1	87	6.1	N/A
	1600	67	4.7	100	7.0	N/A
	(1) Depending on the actual arrangement of the hole centres at the specified distance, the number of open holes N may be increased by 1.					N/A
14.2.5	<b>Test for second characteristic numeral 5 with the 6.3 mm nozzle</b>					—
	The test is made by spraying the enclosure from all practicable directions with a stream of water from a standard test nozzle as shown in Figure 6.					N/A
	The conditions to be observed are as follows:					—
	internal diameter of the nozzle: 6,3 mm;					N/A
	delivery rate: 12.5 l/min ± 5%;					N/A
	water pressure: to be adjusted to achieve the specified delivery rate;					N/A
	core of the substantial stream: circle of approximately 40 mm diameter at 2.5 m distance from nozzle;					N/A
	test duration per square metre of enclosure surface area likely to be sprayed: 1 min;					N/A
	minimum test duration: 3 min;					N/A
	distance from nozzle to enclosure surface: between 2.5 and 3 m					N/A
14.2.6	<b>Test for second characteristic numeral 6 with the 12.5 mm nozzle</b>					—
	The test is made by spraying the enclosure from all practicable directions with a stream of water from a standard test nozzle as shown in Figure 6.					N/A
	The conditions to be observed are as follows:					—
	internal diameter of the nozzle: 12.5 mm;					N/A

IEC 60529			
Clause	Requirement + Test	Result - Remark	Verdict
	delivery rate: 100 l/min $\pm$ 5%;		N/A
	water pressure: to be adjusted to achieve the specified delivery rate;		N/A
	core of the substantial stream: circle of approximately 120 mm diameter at 2.5 m distance from nozzle;		N/A
	test duration per square metre of enclosure surface area likely to be sprayed: 1 min;		N/A
	minimum test duration: 3 min;		N/A
	distance from nozzle to enclosure surface: between 2.5 and 3 m.		N/A
14.2.7	<b>Test for second characteristic numeral 7: temporary immersion between 0.15 and 1 m</b>		—
	The test is made by completely immersing the enclosure in water in its service position as specified by the manufacturer so that the following conditions are satisfied:		—
	a) the lowest point of enclosures with a height less than 850 mm is located 1000 mm below the surface of the water;		N/A
	b) the highest point of enclosures with a height equal to or greater than 850 mm is located 150 mm below the surface of the water;		N/A
	c) the duration of the test is 30 min;		N/A
	d) the water temperature does not differ from that of the equipment by more than 5K.		N/A
	However, a modified requirement may be specified in the relevant product standard if the tests are to be made when the equipment is energized and/or its parts in motion		N/A
14.2.8	<b>Test for second characteristic numeral 8: continuous immersion subject to agreement</b>		—
	Unless there is a relevant product standard, the test conditions are subject to agreement between manufacturer and user,		P
	but they shall be more severe than those prescribed in 14.2.7		P
	And they shall take account of the condition that the enclosure will be continuously immersed in actual use.	Water depth 1500mm, duration 30min	P
14.2.9	<b>Test for second characteristic numeral 9 by high pressure and temperature water jetting</b>		—
	The test is made by spraying the enclosure with a stream of water from a standard test nozzle as shown in Figures 7, 8 and 9.		N/A
	The set-up for measuring the impact force of the water jet is given in Figure 10.		N/A



IEC 60529			
Clause	Requirement + Test	Result - Remark	Verdict
	The distribution force shall be verified at upper and lower limits of distance tolerance range (see Figure 11).		N/A
	a) For small enclosures (largest dimension less than 250 mm), the enclosure shall be mounted on the test device shown in Figure 12.		N/A
	turntable speed: 5 r/min $\pm$ 1 r/min		N/A
	spray positions: 0°, 30°, 60°, 90°		N/A
	The test duration is 30s per position.		N/A
	b) For large enclosures (largest dimension greater than or equal to 250 mm), the enclosure shall be mounted as per intended use. The entire exposed surface area of the enclosure shall be subjected to the spray at some point during the test procedure.		N/A
	spray positions: the enclosure shall be sprayed from all practical directions covering the entire surface area and the spray shall be, as far as possible, perpendicular to the sprayed surface.		N/A
	distance between nozzle and sample under test shall be 175 $\pm$ 25 mm.		N/A
	The test duration is 1 min/m <sup>2</sup> of the calculated surface area of the enclosure (excluding any mounting surface), with a minimum duration of 3 min.		N/A
14.3	<b>Acceptance conditions</b>		—
	After testing in accordance with the appropriate requirements of 14.2.1 to 14.2.9 the enclosure shall be inspected for ingress of water.	No water enters the shell after test	P
	It is the responsibility of the relevant Technical Committee to specify the amount of water which may be allowed to enter the enclosure and the details of a dielectric strength test, if any.		P
	In general, if any water has entered, it shall not:		—
	be sufficient to interfere with the correct operation of the equipment or impair safety;		P
	deposit on insulation parts where it could lead to tracking along the creepage distances;		P
	reach live parts or windings not designed to operate when wet;		P
	accumulate near the cable end or enter the cable if any.		P
	If the enclosure is provided with drain-holes, it should be proved by inspection that any water which enters does not accumulate and that it drains away without doing any harm to the equipment.		N/A

IEC 60529			
Clause	Requirement + Test	Result - Remark	Verdict
	For enclosures without drain-holes, the relevant product standard shall specify the acceptance conditions if water can accumulate to reach live parts		N/A

15	<b>Tests for protection against access to hazardous parts indicated by the additional letter</b>		—
15.1	<b>Access probes</b>		—
	Access probes to verify the protection of persons against access to hazardous parts are given in Table 6.		N/A
15.2	<b>Test conditions</b>		—
	The access probe is pushed against any openings of the enclosure with the force specified in Table 6.		N/A
	If it partly or fully penetrates, it is placed in every possible position, but in no case shall the stop face fully penetrate through the opening.		N/A
	Internal barriers are considered part of the enclosure as defined in 3.1.		N/A
	For tests on low-voltage equipment, a low-voltage supply (of not less than 40 V and not more than 50 V) in series with a suitable lamp should be connected between the probe and the hazardous parts inside the enclosure.		N/A
	Hazardous live parts covered only with varnish or paint, or protected by oxidation or by a similar process, are covered by a metal foil electrically connected to those parts which are normally live in operation.		N/A
	The signal-circuit method should also be applied to the hazardous moving parts of high-voltage equipment.		N/A
	Internal moving parts may be operated slowly, where this is possible.		N/A
15.3	<b>Acceptance conditions</b>		—
	The protection is satisfactory if adequate clearance is kept between the access probe and hazardous parts.		N/A
	In the case of the test for the additional letter B, the jointed test finger may penetrate to its 80mm length, but the stop face (Ø 50 x20 mm) shall not pass through the opening.		N/A
	Starting from the straight position, both joints of the test finger shall be successively bent through an angle of up to 90° with respect to the axis of the adjoining section of the finger and shall be placed in every possible position.		N/A

IEC 60529			
Clause	Requirement + Test	Result - Remark	Verdict
	In case of the tests for the additional letters C and D, the access probe may penetrate to its full length, but the stop face shall not fully penetrate through the opening.		N/A
	See Annex A for further clarification.		N/A
	Conditions for verification of adequate clearance are identical with those given in 12.3.1, 12.3.2 and 12.3.3.		N/A

<b>Annex B</b>	<b>Summary of responsibilities of relevant technical committees</b>	N/A
----------------	---	-----

<b>Annex ZA</b>	<b>(normative)(EN 60529) Other International Publications quoted in this standard with the references of the relevant European Publications</b>	N/A
-----------------	---	-----

**Test Equipment**

Equipment No	Equipment Name	Manufacturer	Model	Calibration information
WXJ088-11	lpx1-x8 waterproof test system	ZHONGZHI	CZ-56K-LY	2023-01-19
WXJ088-10	Dustproof test chamber	ZHONGZHI	CZ-800SC-ZK	2023-01-19
WXJ072-1	stopwatch	TIANFU	PC2810	2023-01-22

## Photo documentation

Details of: **IP6X Before the test**

---



Details of: **IP6X In the test**

---



## Photo documentation

Details of: **IP6X After the test**



Details of: **IPX8 Before the test**



## Photo documentation

Details of: **IPX8 In the test**

---



Details of: **IPX8 After the test**

---



—The report end—